

# AENOR

## Certificate of conformity Plastics

001/007090

AENOR certifies that the organization

### BÄNNINGER KUNSTSTOFFPRODUKTE GMBH

registered office CL BANNINGERSTR, 1 35447 REISKIRCHEN (Alemania)

supplies Polypropylene random with modified cristallinity pipes (PP-RCT) and glass fiber (PP-RCT)/PP-RCT+GF /PP-RCT) for installation of hot and cold water inside the building structure

in compliance with ESPECIFICACIÓN TÉCNICA AL RP 001.78

Description Trademark: WATERTEC  
Fiberglass Content: 6,6%  
Fiberglass Content of the Middle Layer: 20%

See annex for more information.

Production site ATHENSLEBENER WEG, 21 39418 STASSFURT (Alemania)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.78.

This certificate supersedes 001/007090, dated 2020-04-22

First issued on 2020-04-22  
Modified on 2020-07-02  
Validity date 2025-04-22



Rafael GARCÍA MEIRO  
Chief Executive Officer

# AENOR

## Certificate of conformity Plastics

001/007090

### Annex to Certificate

Description Trademark: WATERTEC  
Fiberglass Content: 6,6%  
Fiberglass Content of the Middle Layer: 20%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
3,2	20 - 25	1/10 ; 2/10 ; 4/10 ; 5/8	No
4,0	32 - 40 - 50 - 63 - 75 - 90 - 110 - 125	1/8 ; 2/8 ; 4/8 ; 5/6	No

Original Electronic Certificate

First issued on 2020-04-22  
Modified on 2020-07-02  
Validity date 2025-04-22

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com